


Approaches for monitoring protocols and their practical relevance


Niko Gentile
Lund University, Sweden

**Task 50 3rd Industry Workshop
Aldrans, Austria
March, 10th 2014**


Efficiency Vs. Overall performance



Efficiency Vs. Overall performance



Efficiency Vs. Overall performance





Defining lighting performance



**INTERNATIONAL
YEAR OF LIGHT
2015**



A difficult task



- *INFERNO*



- *PURGATORY*




- *PARADISE*



[¹source: <http://www.libreriamedievale.com/la-divina-commedia-lucchi.html>]


Items



EFFICIENCY

OVERALL PERFORMANCE

Phases




Evaluation protocol methodology



- 2 different calculation methodologies
 - Quick method
 - Comprehensive method
- 2 different baseline
 - Standard baseline
 - Retrofit specific baseline
- Output: complete report with indexes + database

Calculation methodologies

Different levels of complexity, but comparable results



Phases



Output: final report



TASK 50 Advanced Lighting for Retrofit Buildings

EVALUATION OF THE LIGHTING RETROFIT INTERVENTION REPORT

Case n.: **001**
 Location: **Helsingborg, Sweden (56°03'N 12°43'E)**
 Building type: **educational building**
 Year of retrofit: **2012**
 Dfafaafafafaf:
 Dcadafefafacaca:
 Fadfadagagagre:
 Further information: **bla bla bla bla bla**

details





a) One of the classroom during August 2012 with T12 downlight, before the retrofit.
 b) The room after the retrofit with the LED ambient light. Note the homogeneity of the illumination. The furniture and the architecture were not changed during the retrofit.

pictures

	ENERGY	Standard Baseline	Specific Baseline	Retrofit
	Method	—	quick calc	compr
	Final I_e	0,45	0,65	0,72

	LIGHT	Standard Baseline	Specific Baseline	Retrofit
	Method	—	quick	compr
	Final I_e	0,45	0,21	1,00

	USERS	Standard Baseline	Specific Baseline	Retrofit
	Method	—	quick	compr
	Final I_e	0,45	0,13	0,84

	GLOBAL	Standard Baseline	Specific Baseline	Retrofit
	Final I_e	0,45	0,33	0,85

results

The classrooms are 56,7 m² in area and they have sidelight windows facing west. The GWR ratio is about 80%. The architecture of the rooms was not changed, since, despite the high glazed surface, the students did not report any major glare issues or overlighting question.


Regarding the electric lighting, the classrooms were originally equipped with 15 T12 4500K fluorescent tubes. The light fixtures provided a very ununiform illuminance on the working space. The downlight caused severe contrast issues to the pupils.

The electric lighting was replaced with a modern prototype of LED light fixtures for ambient lighting. The illuminance uniformity was highly improved, as well as the ambient illuminance and the cylindrical illuminance in both the center of the room and the teacher position. A lighting scenario control through door switch was introduced. The class can use the following settings: "normal 500 lx", "computer 300 lx" and "AV/projector".

about

- Summary
- Performance at a glance
- Does not substitute the results database

Report: item indexes



Output: global index



- Each single **item index** keep the general information
- The **global index** gives the performance at a glance

Output: database

The screenshot shows the 'Room Lighting' software interface. On the left, there are input fields for 'Name' (Example), 'Luminaire Alternatives' (three entries with File Name 'Elite.lmr' and Catalog Numbers '2G-240A', '2G-440A', and '340S36H'), and 'Properties' (Length: 10, Width: 10, Design Ec: 70, Percent Ceiling Reflectance: 80, Percent Wall Reflectance: 50, Percent Floor Reflectance: 20, Lamp Dirt Depreciation Factor: 85, Ceiling Cavity Height: 0, Room Cavity Height: 7, Floor Cavity Height: 2.5, Luminaire Orientation: Parallel to Length, Luminaire Spacing: Evenly Spaced).

On the right, the 'Results' section displays a table comparing three alternatives:

	Alternative 1	Alternative 2	Alternative 3
Description:	RECESSED ST	RECESSED ST	LOW PROFILE
Manufacturer:	METALUX	METALUX	PARALUX (ME
Lum Required:	3.37	1.78	2.14
Lum Installed:	3	2	2
Footcandles:	62.32	78.84	65.52
Coef. Utilization:	38.79	36.8	40.78
Lamps/Lum:	2	4	3
Total Lumens:	6300	12600	9450
Lumens/Lamp:	3150	3150	3150
Total Watts:	276	360	280
Watts/Lum:	92	180	140
Watts/Sq Foot:	2.76	3.6	2.8
Square Feet:	100	100	100
Rows:	1.5	2	2
Luminaires/Row:	2	1	1
CU (Override):	0	0	0

- The database keeps **all the information**
- Available for „**look in deepness**“

[source: <http://www.elitesoft.com/web/electrical/EtLight.jpg>]

Reference documents

- For the **general approach** to a Monitoring and Verification Protocol
 - IPMVP Vol I (2012) (<http://www.evo-world.org/>)
 - IPMVP Vol III (2006) - Applications
- For the **calculation methodology**
 - Energy – EN 15193:2006
 - Lighting – EN 12464-1:2011, scientific publications
 - Users' satisfaction – Semantic scale by R. Küller, IEA-SHC Task 21 questionnaire